

VOC Content Test Certificate

Tuesday May 13th, 2008

Manufacturer: Sika New Zealand (85 – 91 Patiki Road, Avondale Auckland New Zealand 1746)

Sample Description: Sikaflex Tank single component elastic joint sealant

Date Tested: May 2008 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11 New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3	Sikaflex Tank
Architectural sealant 250 grams per Litre as VOC content material	38 grams per Litre as VOC content material
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Sikaflex Tank
Architectural sealant 250 grams per Litre as VOC content material	38 grams per Litre as VOC content material



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0805-03